



I certify that I have received a copy of these regulations and will comply with the regulations contained herein.

_____ Name _____ Date

INSPECTIONAL SERVICES DIVISION
630-823-5860


General Information

Any facility offering parking for employees or visitors must provide accessible parking for people with disabilities. An accessible parking space consists of a vehicle space and a diagonally striped access aisle. The entire space must be kept clear of obstructions - including ice, snow, shopping cart corrals, trash cans, seasonal garden displays and bicycle racks - at all times.



SIZE AND MARKINGS

Each accessible parking space, except on-street spaces, shall be 16 feet wide, including either an eight-foot or five-foot wide diagonally striped access aisle. The access aisle shall be located on either side of the vehicle space except for angled parking spaces, which shall have the access aisle located on the passenger side of the vehicle space. High-quality yellow paint, manufactured especially for pavement striping, must be used. Adjacent accessible parking spaces can share a common access aisle, except in diagonal parking.



VILLAGE OF HANOVER PARK

ACCESSIBLE PARKING

UPDATED MARCH 2019



Hanover Park^{USA}

2121 Lake Street, Hanover Park, IL 60133

Phone: 630-823-5860, Fax: 630-823-5782, Web: www.hpil.org




Village of Hanover Park

INSPECTIONAL SERVICES DIVISION
630-823-5860

VILLAGE OF HANOVER PARK

ACCESSIBLE PARKING



Note: Access aisles can not be shared in diagonal parking. Provide 8'-0" access aisle for each space.

LOCATION

Accessible parking must be placed on level pavement (2% slope or less) on the shortest accessible route to an accessible entrance. The accessible route, which may include a curb ramp or curb cut, must be installed as close as possible to the accessible entrance it serves. Additionally, a curb ramp must never be built so that it protrudes into or interferes with the diagonally striped access aisle of an accessible space.

SIGNS

A U.S. Department of Transportation R7-8 (Reserved Parking) and R7-1101 (\$250 Fine) sign must be permanently mounted in the center of the accessible parking space. The signs must be placed no more than five feet from the front of the parking space. At a minimum, the bottom of the R7-8 sign must be five feet from the pavement.

SPACES

Where parking spaces are provided for the public, for visitors or for employees, parking spaces shall be provided.

Total Parking Spaces Provided in Facility	Minimum Required Accessible Parking Spaces
1 to 25	1
26 to 50	2
51 to 75	3
76 to 100	4
101 to 150	5
151 to 200	6
201 to 300	7
301 to 400	8
401 to 500	9
501 to 1000	2 percent of total
1001 and over	20, plus 1 for each 100, or fraction thereof, over 1000

Outpatient facilities providing medical care and other services for persons with mobility impairments - 10% of total

Medical facilities specializing in treatment of persons with mobility impairments - 20% of total